

Exhibit F

Exh. F
94-M-29
Return to archives

Highlighted areas indicate fire lanes which shall be 30 feet in width and shall include all service courts. The 30 foot width shall be measured from the face of the curb nearest to the structure.

